

कार्यपालक अभियंता का कार्यालय

(लोक स्वास्थ्य प्रमंडल, जमुई)

पत्रांक..... 2244

दिनांक 22/06/2024

प्रेषक : कार्यपालक अभियंता,
लोक स्वास्थ्य प्रमंडल, जमुई।

सेवा में,

Principal
Oxford Public School
Malaypur,, Jamui

विषय :- जल गुणवत्ता जाँच प्रतिवेदन समर्पित करने के संबंध में।


प्रसंग:- आपका पत्रांक 30 दिनांक 15.06.2024

महाशय,

उपरोक्त विषयक, आपके द्वारा समर्पित जल नमूने की जाँच प्रतिवेदन संलग्न कर समर्पित किया गया है।

अनु०:- यथोपरि।

विश्वासभाजन


कार्यपालक अभियंता,
लोक स्वास्थ्य प्रमंडल, जमुई।

Water Quality Report

Name of Division: P.H. Division, Jamui	District:- Jamui	Sample Receive Date :- 18.06.2024
Type of Sample: Tap Water		Sample Test Date :- 21.06.2024

PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

Sl. No.	Block Name	Panchayat Name	Village Name	Habitation Name	Location Details	pH	Turb. NTU	EC umhol	TDS Mg/l	TH Mg/l	Ca Mg/l	Mg Mg/l	Cl Mg/l	SO4 Mg/l	Alka Mg/l	As Mg/l	T Coli MPN 100 ml
Desirable Limit						6.5-8.5	1.00	.	500	200	75.00	30.00	250.00	200.00	200.00	0.010	
Permissible Limit In absence of alternate source						NR	5.00	.	2000	600	200.00	100.00	1000.00	400.00	600.00	NR	
1	Jamui	Oxford Public school	Oxford Public School			7.5	3	710	597	260	80	14.4	50	10	462	BDL	NEGATIVE

REMARK:- FIT FOR DRINKING

Amit Kumar
21.06.2024
 Analyst
 P.H. Division, Jamui

[Signature]
 Executive Engineer
 P.H. Division, Jamui